

## Update of cryogenic requirements for S3 - 7 SC triplets

### Requirements for the cold box in the S3 vault

Entrance elevator and doorway dimensions and distribution line layout from Franck  
Helium cooling requirements based on analysis below with some margin:

#### Refrigeration at 4.5 K:

75 W (50 W estimated with 50% margin including allowance for junction box and storage dewar at cold box)

#### Cold gas at 50K:

10 g/s at 50 K returned at 65 K (~50% margin)

5 g/s at 50 K returned at 300 K (~50% margin)

#### Helium Compressors:

To provide high pressure helium and suction pressure return from a distance of 100 m from the cold box which is in the underground cave.

### Heat loads

#### 4.5 K

##### Each cryostat:

2 4.5 K valves per triplet (2W)

1 vacuum break per triplet (1W)

static load per triplet including support links (2W)

thermal load of 9 pairs of 400 amp HTS leads (0.05W)

**Total for 7 triplets 35W**

##### Distribution line:

Assume 50 m at 0.3 W/m: 15W

**Total 4.5 K load: 50 W**

#### 50 K

##### Each cryostat:

1 g/s at 50 K returned at 60 K (equivalent to 52 W, or one liter/hr LN2)

0.5 g/s at 50K returned at 300 K to compressor suction (to cool 9 pair of 400 amp leads per cryostat)

##### Distribution line:

Additional 1.5 W/m times 50 m (to be confirmed by Franck), 75 W total adding small amount to the 60 K cold gas return. Assume net effect is to return cold gas at ~65 K.

**Total load at 50K:**

7 g/s returned at 65 K

3.5 g/s returned at 300K to pump suction